



Ref. Certif. No.

FI 7599

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST  
CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE)  
CB SCHEMESYSTEME CEI D'ACCEPTATION MUTUELLE DE  
CERTIFICATS D'ESSAIS DES EQUIPEMENTS  
ELECTRIQUES (IECEE) METHODE OC

## CB TEST CERTIFICATE

## CERTIFICAT D'ESSAI OC

Product  
Produit

UPS (uninterrupted power supply)

Name and address of the applicant  
Nom et adresse du demandeurEaton Power Quality Oy,  
Koskelontie 13,  
FI-02920 ESPOO, FINLANDName and address of the manufacturer  
Nom et adresse du fabricant

Same as applicant

Name and address of the factory  
Nom et adresse de l'usine

Same as applicant

Note: When more than one factory, please report on page 2  
Note: Lorsque il y plus d'une usine, veuillez utiliser la 2<sup>ème</sup> page Additional Information on page 2Ratings and principal characteristics  
Valeurs nominales et caractéristiques principales380/400/415 VAC, 50/60Hz, 95/90/86 A, input power 50kW  
output power 50kW,  
380/400/415 VAC, 50/60Hz, 95/90/86 A, input power 50kW  
output power 40kW,  
380/400/415 VAC, 50/60Hz, 95/90/86 A, input power 50kW  
output power 30kWTrademark (if any)  
Marque de fabrique (si elle existe)

Eaton

Type of Manufacturer's Testing Laboratories used  
Type de programme du laboratoire d'essais constructeur

TMP

Model / Type Ref.  
Ref. De type93PM-50(50)-MBS-BB-YxZAh,  
93PM-40(50)-MBS-BB-YxZAh,  
93PM-30(50)-MBS-BB-YxZAh.Additional information (if necessary may also be reported  
on page 2)  
Les informations complémentaires (si nécessaire,, peuvent  
être indiqués sur la 2<sup>ème</sup> page

Output power selected by software configuration.

 Additional Information on page 2A sample of the product was tested and found  
to be in conformity with  
Un échantillon de ce produit a été essayé et a été  
considéré conforme à laIEC 62040-1:2008 including Cenelec common  
modifications.As shown in the Test Report Ref. No. which forms part of  
this Certificate  
Comme indiqué dans le Rapport d'essais numéro de  
référence qui constitue partie de ce Certificat

268241-1

This CB Test Certificate is issued by the National Certification Body of Finland  
Ce Certificat d'essai OC est établi par l'Organisme National de Certification de Finlande

SGS Fimko Ltd

Date: 21 November 2012

Signature:

Timo Silonsaari  
Specialist





Ref. Certif. No.

**FI 7599**

93PM-50(50)-MBS-BB-YxZAh,  
93PM-40(50)-MBS-BB-YxZAh,  
93PM-30(50)-MBS-BB-YxZAh.

93PM-50(50) indicates the type of equipment and input/output power. Y and Z is a number between 1-9 Y indicates number of battery strings and Z capacity of one battery. MBS and BB-YxZAh indicates the configuration of the UPS, markings can be left empty if not provided with the delivery.

**Additional information (if necessary)**  
**Information complémentaire (si nécessaire)**

Date: 21 November 2012

Signature:

**SGS Fimko Ltd**

*Timo Silonsaari*  
Timo Silonsaari  
Specialist

